

CITY OF ANACORTES 2006 CSO REPORT

GENERAL INFORMATION

The NPDES permit number WA-002025-7 is issued to the City of Anacortes. The permit identifies CSO's by discharge number. This report will refer to the CSO's as they are identified in the permit. The CSO's are located as identified in the following table:

Discharge No.	Location		Receiving Water
002	Northernmost end of B Avenue	Latitude: 48 30'55" Longitude: 122 38'03"	Guemes Channel
003	Northernmost end of M Avenue	Latitude: 48 31'14" Longitude: 122 36'56"	Guemes Channel
004	Northernmost end of Q Avenue	Latitude: 48 31'18" Longitude: 122 36'34"	Guemes Channel

Discharge number 002 was monitored with a Marsh-McBirney Model 256A flow meter.

The Model 256A flow meter measures level and velocity and reports flows to the treatment plant via a radio telemetry system. When the meter is active the plant control system is programmed to activate an alarm that indicates overflow at this CSO. The plant data acquisition system computes daily flow totals.

Discharge number 003 was monitored with Marsh-McBirney Model 260 portable flow meter system.

The Model 260 flow meter measures level and velocity. The level and velocity measurements are stored in the meter, in the field. The meter is periodically "uploaded" to a laptop computer. During the upload, level, velocity and error logs are transferred to the computer. The Marsh-McBirney Co. Floware for Windows version 2.80.2.8 software package was used to compute flows from this information.

The following information applies to the flow meter systems at Discharge #002 and #003:

1. The flow meter level and velocity-sensing device is located directly in the outfall pipe.
2. The flow meters detect levels in excess of 0.4 inches. In pipe flows that do not reach or exceed 0.4 inches are not measured.
3. The flow meters detect velocity only when the level is in excess of one inch. Total flow is computed from the velocity and level measurements, therefore the flow cannot be totaled unless the level in the pipe exceeds one inch.
4. The flow meters were set to record the level and velocity for 60 seconds, once every fifteen minutes.
5. Flow information is reported from 12:00 p. m. (midnight) to 11:59:59 p. m. (midnight) on the indicated day.

Discharge number 004 was monitored with a Krohne Magmeter, type IFS-4000/PF. The rate of flow measured by this meter is reported to the wastewater treatment plant via a radio telemetry system. The plant data acquisition system totals the flow data and includes the information on plant reports. A float switch also monitors this CSO. When the level in the sewer system approaches the height of the overflow weir the float is activated. This float switch activates an alarm at the wastewater treatment. Plant personnel are alerted of the impending CSO activity.

Rainfall reported is recorded at the Anacortes Wastewater Treatment Plant by a tipping bucket rain gauge. Rainfall totals are reported from 7:00 a. m. on the indicated day to 6:59:59 a. m. on the following day.

Daily flow totals for Discharge #002 and #004 are included in appendix A.

Daily flow totals for Discharge #003 are included in appendix B.

Rainfall data is included in appendix C.

Appendix D includes a map of the City of Anacortes, including wastewater pump stations identified by number.

Appendix E contains information from previous annual CSO reports and overflow information for CSO discharge #004.

Appendix F contains a copy of the public notice advertised in the Anacortes American, the City of Anacortes official newspaper of record, announcing the availability of the annual CSO report.

**DETAIL OF FREQUENCY, VOLUME AND COMPARISON TO BASELINE
CONDITION, DISCHARGE NO. 002, "B" AVE. CSO**

FREQUENCY and VOLUME

As stated previously, discharge number 002 was monitored with a Marsh-McBirney Model 256A flow meter. Flow information from the meter is transmitted to the treatment plant via a radio telemetry system. Reports of this flow data are generated on a daily and monthly basis. This meter occasionally reports discharge amounts of from one to three gallons. These amounts reported are a result of noise from the flow meter or in the telemetry system. The day after this shows up on the report the flow channel has been examined and no evidence of any overflow exists.

There are no overflow events to report for 2006.

Total rainfall measured at the Anacortes Wastewater Treatment Plant in 2005 was 26.12".

Discharge from this CSO can be caused by failure of an adjacent wastewater pump (PS #3) station. No overflow events occurred in 2006 as a result of failure of PS #3. During the year 2000 significant improvements were made to PS #3. Most notably the pump station is now connected to a standby emergency power generator.

COMPARISON TO BASELINE

There has not been an overflow event at this CSO since 1997. Overflow events and the annual baseline are charted and included at the end of this section.

DETAIL OF FREQUENCY, VOLUME AND COMPARISON TO BASELINE CONDITION, DISCHARGE NO. 003, "M" AVE. CSO

The CSO is monitored with a portable flow meter. The flow meter is routinely read on a monthly basis. A meter was in service continuously for the entire monitoring period.

There were no overflow events in 2006.

Total rainfall measured in 2006 was 26.12"

COMPARISON TO BASELINE

There has not been an overflow event at this CSO since 1997. Overflow events and the annual baseline are charted and included at the end of this section.

**DETAIL OF FREQUENCY, VOLUME AND COMPARISON TO BASELINE
CONDITION, DISCHARGE NO. 004, "Q" AVE. CSO**

Previous reports contain considerable detail explaining the history of this CSO.

There were no overflow events in 2006.

Total rainfall measured in 2006 was 26.12"

COMPARISON TO BASELINE

Flow monitoring was installed on this CSO in January of 1998. The only measured overflow event on this CSO since monitoring was installed occurred in 2003.

CSO REDUCTION ACCOMPLISHMENTS

1. A storm sewer directly connected to the sanitary sewer was discovered in 1998. The storm sewer serves a three-square block area, Commercial Avenue to O Avenue (one block) and from 10th Street to 13th Street. This area is in the down town area of Anacortes and is mostly asphalt. The City of Anacortes developed a plan to separate this storm drainage system from the sanitary sewer system. This plan will be implemented during 2007.
2. Replaced 695 feet of 8 inch sewer line, 345 feet of 12 inch sewer line, and replaced 5 old and leaking sewer manholes.
3. A block (from 9th Street to 10th Street of Commercial Avenue) of the Central Business District sidewalks was replaced, and the building roof drains from two commercial buildings and one parking lot were collected and diverted into the storm sewer system.

PLANNED IMPROVEMENTS

The improvements planned for 2007 are as follows:

1. A block (from 10th Street to 11th Street of Commercial Avenue) of the Central Business District sidewalks will be replaced, and the building roof drains from two commercial buildings and one parking lot will be collected and diverted into the storm sewer system.
2. The City of Anacortes will enter into a contract to remove the storm sewer connection to the sanitary sewer system at Commercial Avenue and 13th Street.
3. The City of Anacortes is preparing an update the Comprehensive Sanitary Sewer Plan including an update to the Combined Sewer Overflow Reduction Plan. The CSO Reduction Plan update is intended to comply with the conditions described in paragraph S12 of the NPDES permit. Specific projects will be identified in this plan to remove additional storm water from the sanitary sewer collection system.